

FORZA REFERENCE


GP10.8A39.

Rating according to BS EN ISO 717-1:1997

Rw(C:Ctr)= 39(-1;-3)dB

Test Number:	040311.Z03b		Air Temperature (°C):	20
Testcentre/Client:	Rosenheim/Glaverbel S.A		Air Humidity (%):	30
Test Date:	11/03/2004		Receiving room Volume (m³):	67.5
Sample height (m):	1.48		Source Room volume (m3):	101
Sample width (m):	1.23		Sample weight (kg/m²):	45.32
Product:	10.8mm AGC Stratophone (55.2)			

Frequency f Hz	Sound Reduction Index, dB	
	1/3 Oct	1/1 Oct
50	37.2	
63	31.9	
80	32.3	
100	30.8	
125	27.3	
160	30.7	
200	30.7	
250	31.5	
315	32.3	
400	33.4	
500	35.2	
630	37.4	
800	38.8	
1000	39.8	
1250	40.2	
1600	40.3	
2000	39.6	
2500	41.0	
3150	44.9	
4000	48.5	
5000	51.1	
6300+		
8000+		
10000+		
Average 100-3150		



Notes	5mm acoustic putty between timber liner and glass edge