


FORZA REFERENCE
ASG44.32A30S



Rating according to BS EN ISO 717-1:2013

Rw(C:Ctr)= 32 (-1:-2) dB

Test Number:	19	Air Temperature (°C):	13.5
Testcentre/Client:	FORZA	Air Humidity (%):	51300
Test Date:	25/02/2016	Receiving room Volume (m³):	115
Area test sample m2	2.31	Source Room volume (m3):	
		Sample weight (kg/m²):	
Product:	44mm timber particleboard core in a generic aluminium frame **		
Identification:	Seals: Head and jambs - ST1009 / 1no. 20 x 4		
	Threshold ST422		



Notes	+ designates frequency beyond standard and not UKAS accredited
	*designated measurement corrected for background
	** As frame is generic - please regard this data as a guide only