

FORZA REFERENCE


GS8.8A37

Rating according to BS EN ISO 717-1:1997

Rw(C:Ctr)= 37(0;-2)dB

Test Number:	AC3665	Air Temperature (°C):	22
Testcentre/Client:	BBRI/Glaverbel S.A	Air Humidity (%):	57
Test Date:	19/09/2003	Receiving room Volume (m³):	49.2
Sample height (m):	1.48	Source Room volume (m³):	50.5
Sample width (m):	1.23	Sample weight (kgs):	38.2
Product:	8.8mm AGC Stratophone (44.2)		

Frequency f Hz	Sound Reduction Index, dB	
	1/3 Oct	1/1 Oct
50		
63		
80		
100	24.7	
125	27.0	
160	29.5	
200	27.8	
250	31.0	
315	32.2	
400	32.4	
500	34.2	
630	36.6	
800	36.9	
1000	38.2	
1250	39.6	
1600	39.7	
2000	39.9	
2500	38.2	
3150	39.1	
4000	43.2	
5000	47.4	
6300+		
8000+		
10000+		
Average 100-3150		



Notes	5mm acoustic putty between timber liner and glass edge