

FORZA REFERENCE


GS6.8A36

Rating according to BS EN ISO 717-1:1997

Rw(C:Ctr)=36(0;-3)

Test Number:	040311.Z01b		Air Temperature (°C):	20
Testcentre/Client:	Rosenheim/Glaverbel S.A		Air Humidity (%):	30
Test Date:	11/03/2004		Receiving room Volume (m³):	67.5
Sample height (m):	1.48		Source Room volume (m3):	101
Sample width (m):	1.23		Sample weight (kgs):	29.1
Product:	6.8mm AGC Stratophone (33.2)			

Frequency f Hz	Sound Reduction Index, dB	
	1/3 Oct	1/1 Oct
50	41.9	
63	28.7	
80	26.0	
100	26.3	
125	23.6	
160	27.5	
200	27.4	
250	28.9	
315	29.2	
400	30.3	
500	32.2	
630	34.5	
800	36.1	
1000	37.4	
1250	38.2	
1600	38.8	
2000	39.2	
2500	39.6	
3150	39.3	
4000	41.1	
5000	44.4	
6300+		
8000+		
10000+		
Average		
100-3150		



Notes	5mm acoustic putty between timber liner and glass edge



forza-doors.com
01403 711 126
tech@forza-doors.com